

PLANNING DIVISION COMMENTS

DATE: December 13, 2004
PROJECT NAME: Container Properties Demolition Building F
PLAN CHECK NO.: D04-425

Plan Reviewer: Contact Nora Gierloff at (206) 431-3670 if you have any questions regarding the following comments.

Building F and the storage tank appear to be within 200' of the mean high water mark of the Duwamish River. Please show the MHWM on the site plan and a line 200' landward. Please also document the dollar value of all of the work (this permit as well as D04-430) that will occur within that 200' zone. If the total exceeds \$5,000 a shoreline permit will be required prior to demolition.

